



DECLARATION OF COMPLIANCE for EQUIPMENTS¹ for distributed generation
for the application of §2.10, §2.13 and annex 4 (automatic decoupling system)
according to the SynergriD prescription C10/11 revision 04.06.2012

The undersigned, Manufacturer: Enphase Energy Inc Represented by: D.W. Strijks
Address: 1420 North McDowell Blvd Country: The Netherlands
Petaluma, CA 94954 Telephone: +31 6 12876130.....

Hereby declares that each equipment listed on the page hereafter satisfies the following conditions:

- 1. The equipment meets the criteria as described in the SynergriD prescription C10/11 ed. 06.2012, § 2.10 and 2.13 (see also §5.7.3.3 of the "Anwendungsregel" VDE-AR N 4105: 2011-08)
- 2. In case of an installation ≤ 10 kVA equipped with an automatic decoupling system:
 - 2.1. If the equipment is connected to a Belgian distribution grid, the configuration of the automatic decoupling system complies with the parameterization as required in the SynergriD prescription C10/11 ed. 06.2012, annex 4, §3 (see also §6.5.2 of the "Anwendungsregel" VDE-AR N 4105 2011-08).
 - 2.2. The automatic decoupling system of the equipment fulfills:
 - a. either the type tests required in §6 of the « Preliminary standard » DIN V VDE V 0126-1-1 of February 1, 2006, amended in February 2012;
 - b. or the type tests as referred to in §9.4 of the "Anwendungsregel" VDE-AR N 4105 2011-08.

In order to prove this, either a **certificate** which demonstrates the required compliance, or the necessary **test reports**, is (are) provided to SynergriD. The certificate is issued by a EN 45011 (or ISO 17065:2012) body certified for these materials, or the test reports are issued by a laboratory accredited for these tests (ISO 17025:2005 or ISO 17065:2012 accreditation). The certificate or the test reports prove that the automatic decoupling system complies with the requirements of the type tests as described above.




Done at (place): EnTEST Laboratories Published on the website of SynergriD on:
On (date): 30 August 2018 Stamp SynergriD: SYNERGRID a.s.b.l. - V.Z.W.
Signature: *D.K.* Galerie Ravensteingalerij 3/6
Stamp manufacturer: ENPHASE BE-1000 Bruxelles/Brussel
T.V.A./B.T.W. BE 0402.958.091

¹ This attestation refers to the components of the facility which assure the criteria of C10/11 ed. 06.2012, § 2.10 and 2.13 and, if necessary, contain the automatic decoupling system in conformity with annex 4; in most cases this is the inverter or the generator itself.

1. Equipments ≤ 10 kVA, provided with an automatic decoupling system

NOTE: Single phase inverters > 5 kVA are not accepted, unless an exception is permitted by the local DNO (distribution network operator) and explicitly mentioned on its website. See also C10/11 §2.4 (+ footnote 5) and its FAQ question 1.2.

BRAND	SERIES	REFERENCE MODEL or TYPE	FIRMWARE VERSION	maximum AC POWER (VA)	VOLTAGE	
					MONO	TRI
Enphase	IQ-Series	IQ7X-96-X-Y-INT + Q-Relay-1PH-INT or Q-Relay-3PH-INT	520-00082-r01- v02.14.02	320	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Enphase	IQ-Series	IQ7PLUS-72-X-Y-INT+ Q-Relay-1PH-INT or Q-Relay-3PH-INT	520-00082-r01- v02.14.02	295	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Enphase	IQ-Series	IQ7-60-X-Y-INT+ Q-Relay-1PH-INT or Q-Relay-3PH-INT	520-00082-r01- v02.14.02	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>
					<input type="checkbox"/>	<input type="checkbox"/>

 **SYNERGRID a.s.b.l. - v.z.w.**
Galerie Ravensteingalerij 3/6
BE-1000 Bruxelles/Brussel
T.V.A./B.T.W. BE 0402.958.091

2. Equipments > 10 kVA

BRAND	SERIES	REFERENCE MODEL or TYPE	FIRMWARE VERSION	Q-Relay-1PH-INT	VOLTAGE	
					MONO	TRI
Brand name	Series name	Reference model 1	Version x.y		<input type="checkbox"/>	<input type="checkbox"/>
Brand name	Series name	Reference model 2	Version x.y		<input type="checkbox"/>	<input type="checkbox"/>
Brand name	Series name	Reference model 3	Version x.y		<input type="checkbox"/>	<input type="checkbox"/>
Brand name	Series name	Reference model 4	Version x.y		<input type="checkbox"/>	<input type="checkbox"/>