

DECLARATION OF COMPLIANCE for EQUIPMENTS¹ for distributed generation

for the application of **§2.10, §2.13 and annex 4** (automatic decoupling system) according to the Synergrid prescription **C10/11 revision 04.06.2012**



The undersigned,

Manufacturer: JIANGSE GOODWE POWER SUPPLY TECHNOLOGY CO.,..... Represented by: XieJing
Address: No. 189 Kun Lun Shan Road, Suzhou New District..... Country: CHINA.....
Jiangsu, P.R. CHINA Telephone: +86 512 6239 7998.....

Hereby declares that each equipment listed on the page hereafter satisfies the following conditions:

1. The equipment meets the criteria as described in the Synergrid prescription C10/11 ed. 06.2012, § 2.10 and 2.13 (see also §5.7.3.3 of the "Anwendungsregel" VDE-AR N 4105: 2011-08)
2. In case of an installation ≤ 10 kVA equipped with an automatic decoupling system:
 - 2.1. If the equipment is connected to a Belgian distribution grid, the configuration of the automatic decoupling system complies with the parameterization as required in the Synergrid prescription C10/11 ed. 06.2012, annex 4, §3 (see also §6.5.2 of the "Anwendungsregel" VDE-AR N 4105 2011-08).
 - 2.2. The automatic decoupling system of the equipment fulfills:
 - a. either the type tests required in §6 of the « Preliminary standard » DIN V VDE V 0126-1-1 of February 1, 2006, amended in February 2012;
 - b. or the type tests as referred to in §9.4 of the "Anwendungsregel" VDE-AR N 4105 2011-08.

In order to prove this, either a **certificate** which demonstrates the required compliance, or the necessary **test reports**, is (are) provided to Synergrid. The certificate is issued by a EN 45011 (or ISO 17065:2012) body certified for these materials, or the test reports are issued by a laboratory accredited for these tests (ISO 17025:2005 or ISO 17065:2012 accreditation). The certificate or the test reports prove that the automatic decoupling system complies with the requirements of the type tests as described above.

Done at (place): GoodWe Research Department Test Lab Published on the website of Synergrid on:
On (date): 2016.08.01 Stamp Synergrid:
Signature: XieJing
Stamp manufacturer: JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD



¹ This attestation refers to the components of the facility which assure the criteria of C10/11 ed. 06.2012, § 2.10 and 2.13 and, if necessary, contain the automatic decoupling system in conformity with annex 4; in most cases this is the inverter or the generator itself.

1. Equipments ≤ 10 kVA, provided with an automatic decoupling system

NOTE: Single phase inverters > 5 kVA are not accepted, unless an exception is permitted by the local DNO (distribution network operator) and explicitly mentioned on its website. See also C10/11 §2.4 (+ footnote 5) and its FAQ question 1.2.

BRAND	SERIES	REFERENCE MODEL or TYPE	FIRMWARE VERSION	maximum AC POWER (VA)	VOLTAGE	
					MONO	TRI
GOODWE	NS	GW3600-NS	V1.02.02	3680	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GOODWE	NS	GW4200-NS	V1.02.02	4200	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GOODWE	NS	GW5000-NS	V1.02.02	5000	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GOODWE	DNS	GW3000D-NS	V1.02.02	3000	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GOODWE	DNS	GW3600D-NS	V1.02.02	3680	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GOODWE	DNS	GW4200D-NS	V1.02.02	4200	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GOODWE	DNS	GW5000D-NS	V1.02.02	5000	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GOODWE	DT	GW8000-DT	V1.09.09	8000	<input type="checkbox"/>	<input checked="" type="checkbox"/>
GOODWE	DT	GW9000-DT	V1.09.09	9000	<input type="checkbox"/>	<input checked="" type="checkbox"/>
GOODWE	DT	GW10KN-DT	V1.09.09	10000	<input type="checkbox"/>	<input checked="" type="checkbox"/>

2. Equipments ≤ 10 kVA,

BRAND	SERIES	REFERENCE MODEL or TYPE	FIRMWARE VERSION	maximum AC POWER (VA)	VOLTAGE	
					MONO	TRI
GOODWE	DT	GW25K-DT	V1.14.14	25000	<input type="checkbox"/>	<input checked="" type="checkbox"/>

